

(TO BE PUBLISHED IN PART-IV OF THE DELHI GAZETTE-EXTRA ORDINARY)
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
(DEPARTMENT OF POWER)
DELHI SECRETARIAT, 8TH LEVEL, B-WING
NEW DELHI – 110002

No.F.11(99)/2005/Power/1399-1413


Dated : the 30th April, 2015

NOTIFICATION

No. F.11(99)/2005/Power – In exercise of the powers conferred by regulation 43 of the Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations, 2010 as amended upto date read with Govt. of India notification no. 50217(E) dated 20th Feb 2014, the Government of National Capital Territory of Delhi, hereby, notify that all electrical installations and apparatus of Distribution utilities operating in Delhi having voltage exceeding 11000 volts shall be inspected by Electrical Inspector, before commencement of supply or recommencement after shut down for six months and above, for ensuring observance of safety measures specified under the said regulations.

For electrical installations and apparatus of all others except Distribution utilities, inspection, of Electrical Inspector is mandatory for voltage exceeding 650 volts.

By order and in the name of the Lt. Governor
Of the National Capital Territory of Delhi,


(Alka Sharma)
Dy. Secretary (Power)