



TATA POWER-DDL

B/C

TPDDL/REGULATORY/2024-25/03/ 411
Mar 04, 2025

Office of the Head (Regulatory)

The Secretary

Delhi Electricity Regulatory Commission
Viniyamak Bhawan, C-Block, Shivalik
Malviya Nagar, New Delhi-110017

Subject: Submission of details of electrical accidents and action taken in line with DERC (Compensation to Victims of Electrical Accidents) Regulations, 2024 for the month of Feb 2025.

Dear Sir,

The Hon'ble Commission had notified the DERC (Compensation to Victims of Electrical Accidents) Regulations, 2024 which was published in the official gazette on 26.07.2024. With their publication in the official gazette, these Regulations have come into force from 26.07.2024 as provided in these Regulations.

Further, these Regulations provide for submission to the Hon'ble Commission by 15th of every succeeding month, the details of electrical accidents occurring within the respective jurisdiction of the distribution licensee and action taken thereon in accordance with these Regulations. Same is reproduced below for ready reference:

"18. Information to the Commission: -

The generating company or transmission licensee or distribution licensee shall submit to the Commission by 15th of every succeeding month, the details of electrical accidents occurring within their respective jurisdiction and action taken thereon in accordance with these Regulations."

Accordingly, Tata Power-DDL is submitting the report, enclosed herewith as **Annexure-1**, for the month of Feb 2025 i.e. 01.02.2025 to 28.02.2025.

We hope the Hon'ble Commission would find the above in order.

Yours Sincerely,
For **Tata Power Delhi Distribution Ltd.**

Ritu Gupta
Head (Regulatory)

Encl: As mentioned above

TATA POWER DELHI DISTRIBUTION LIMITED

(A Tata Power and Delhi Government Joint Venture)

Regd. & Corp. Office : NDPL House Hudson Lines Kingsway Camp Delhi - 110 009

Website : www.tatapower-ddl.com CIN No. : U40109DL2001PLC111526

Email : tpddl@tatapower-ddl.com Tel. : 011-6611 2272

Annexure-1

S No.	Date of Incident	Zone/District	Address/Location	Brief Detail	TPDDL network involved?	Fatal/non-fatal	Remarks
1	23.02.2025	Streetlight Pole in Zone-517 (D-Narela)	Shamshan Ghat Road, Village-Bakoli, Near JP Dharam Kanta	<p>At about 10:00 PM on 23.02.2025, Zonal Shift Officer of Zone-517 (Bakhtawarpur) received information over phone from I.O. Sh. Jagwinder malik (Delhi Police) that a Horse got electric shock at Shamshan Ghat Road Village Bakoli near JP Dharam Kanta. Soon after, on duty Zonal Shift officer (ZSO) along with night duty Breakdown staff visited the site in presence of I.O. Sh. Jagwinder Malik. Neighbours informed that the horse owner had tied the horse with the GI pole of a streetlight. However, he was unaware of the hazards of tying the horse with electric streetlight pole. On further investigation, it was observed that the pole was in tilted position which was probably due to being hit by a vehicle, which resulted in breakage of cable and leakage in the electric pole.</p> <p>Deceased – Pet Horse</p>	Yes	Fatal	The Electrical Inspector has been informed and the enquiry report is awaited.

