



TATA POWER-DDL

TPDDL/REGULATORY/2026-27/03/ 09

Office of the Head (Regulatory)

Apr 09, 2026

The Secretary

Delhi Electricity Regulatory Commission
Viniyamak Bhawan, C-Block, Shivalik
Malviya Nagar, New Delhi-110017

Subject: Submission of details of electrical accidents and action taken in line with DERC (Compensation to Victims of Electrical Accidents) Regulations, 2024 for the month of March 2026.

Dear Sir,

The Hon'ble Commission had notified the DERC (Compensation to Victims of Electrical Accidents) Regulations, 2024 which was published in the official gazette on 26.07.2024. With their publication in the official gazette, these Regulations have come into force from 26.07.2024 as provided in these Regulations.

Further, these Regulations provide for submission to the Hon'ble Commission by 15th of every succeeding month, the details of electrical accidents occurring within the respective jurisdiction of the distribution licensee and action taken thereon in accordance with these Regulations. Same is reproduced below for ready reference:

"18. Information to the Commission: -

The generating company or transmission licensee or distribution licensee shall submit to the Commission by 15th of every succeeding month, the details of electrical accidents occurring within their respective jurisdiction and action taken thereon in accordance with these Regulations."

Accordingly, Tata Power-DDL is submitting the report, enclosed herewith as **Annexure-1**, for the month of March 2026 i.e. 01.03.2026 to 31.03.2026.

We hope the Hon'ble Commission would find the above in order.

Yours Sincerely,
For Tata Power Delhi Distribution Ltd.

Ritu Gupta
Head (Regulatory)

Encl: As mentioned above

Annexure-1

S No.	Date of Incident	Zone/ District	Address/ Location	Brief Detail	TPDDL network involved?	Fatal/ non- fatal	Remarks
1	02.03.2026	Zone - 521/ Bawana	Factory No. N 271, Sector - 1, DSIDC, Bawana Industrial area	<p>Construction work was being carried out at site and consumer had encroached upon network by erecting a temporary structure for construction purpose. During construction activity, a person came into vicinity of 11 kV Bare Network while carrying an iron rod. The iron rod inadvertently came into contact with 11 kV network, which resulted into an incident.</p> <p>Information regarding incident was received through a letter submitted at TPDDL District office Bawana by Investigating office from Office of SHO Bawana.</p> <p>A site visit was conducted along with the External EI on 16.03.2026; however, the EI report has not been received yet.</p>	Yes	Fatal	The enquiry report from the Electrical Inspector is awaited.

