

Rolling AT&C Loss (FY 18-19)									
Name of District	Energy Input (MU)	Energy Billed (MU)	D&B Losses (%)	Amount Billed (Rs. Cr.)	Amount Realized (Rs. Cr.)	Coll. Eff. (%)	Average Rate of billing (Rs./Kwh)	Energy Realized (MU)	AT&C Losses (%)
Badli	660.71	613.11	7.21%	570.71	572.97	100.40%	9.31	615.54	6.84%
Bawana	1381.97	1206.06	12.73%	1238.09	1240.16	100.17%	10.27	1208.08	12.58%
Civil Lines	776.78	729.80	6.05%	624.24	618.58	99.09%	8.55	723.19	6.90%
Keshav Puram	680.16	641.70	5.66%	610.46	612.20	100.28%	9.51	643.52	5.39%
Mangolpuri	789.20	719.92	8.78%	544.30	547.20	100.53%	7.56	723.76	8.29%
Model Town	530.11	503.85	4.95%	434.97	432.58	99.45%	8.63	501.09	5.47%
Moti Nagar	819.57	769.94	6.06%	747.03	748.11	100.14%	9.70	771.05	5.92%
Narela	1176.13	1056.62	10.16%	1032.96	1032.25	99.93%	9.78	1055.89	10.22%
Pitam Pura	650.27	609.86	6.22%	543.08	543.20	100.02%	8.91	609.99	6.20%
Rohini	881.43	832.71	5.53%	689.13	686.28	99.59%	8.28	829.27	5.92%
Shakti Nagar	353.58	331.47	6.25%	291.71	293.07	100.47%	8.80	333.02	5.81%
Shalimar Bagh	931.08	852.33	8.46%	646.63	647.29	100.10%	7.59	853.20	8.36%
<b>TATA Power-DDL Total</b>	<b>9631.00</b>	<b>8867.37</b>	<b>7.93%</b>	<b>7973.31</b>	<b>7973.91</b>	<b>100.01%</b>	<b>8.99</b>	<b>8868.03</b>	<b>7.92%</b>

Note:-

All the above figures have been truncated to two decimal places. Energy Realized (MU) data (at TATA Power-DDL level) has been calculated as per average billing rate (at TATA Power-DDL level).