

**Annual AT&C Loss (FY2020-2021)**

Name of District	Energy Input (MU)	Energy Billed (MU)	D&B Losses (%)	Amount Billed (Rs. Cr.)	Amount Realized (Rs. Cr.)	Coll. Eff. (%)	Average Rate of billing (Rs./Kwh)	Energy Realized (MU)	AT&C Losses (%)
<b>Badli</b>	572.64	506.25	11.59%	489.27	496.17	101.41%	9.66	513.38	10.35%
<b>Bawana</b>	1211.33	1049.85	13.33%	1207.53	1227.81	101.68%	11.50	1067.48	11.88%
<b>Civil Lines</b>	717.65	698.06	2.73%	614.19	612.99	99.80%	8.80	696.70	2.92%
<b>Keshav Puram</b>	776.54	732.97	5.61%	687.64	689.81	100.32%	9.38	735.28	5.31%
<b>Mangolpuri</b>	596.14	563.84	5.42%	383.83	388.29	101.16%	6.81	570.40	4.32%
<b>Model Town</b>	627.77	596.41	4.99%	471.62	469.80	99.62%	7.91	594.12	5.36%
<b>Moti Nagar</b>	717.87	681.99	5.00%	655.97	657.56	100.24%	9.62	683.64	4.77%
<b>Narela</b>	1015.34	901.51	11.21%	932.72	944.94	101.31%	10.35	913.32	10.05%
<b>Pitam Pura</b>	602.66	576.48	4.34%	489.56	490.42	100.17%	8.49	577.49	4.18%
<b>Rohini</b>	1014.10	981.81	3.18%	754.81	758.88	100.54%	7.69	987.11	2.66%
<b>Kirari</b>	373.88	334.90	10.43%	212.21	212.33	100.06%	6.34	335.09	10.38%
<b>Shalimar Bagh</b>	724.20	686.37	5.22%	487.42	490.87	100.71%	7.10	691.23	4.55%
<b>TPDDL Total</b>	<b>8950.12</b>	<b>8310.43</b>	<b>7.15%</b>	<b>7386.76</b>	<b>7439.86</b>	<b>100.72%</b>	<b>8.89</b>	<b>8370.17</b>	<b>6.48%</b>

Note:-

All the above figures have been truncated to two decimal places. Energy Realized (MU) data (at TPDDL level) has been calculated as per average billing rate(at TPPDL level).