

Annual AT&C Loss (FY 16-17)

Name of District	Energy Input (MU)	Energy Billed (MU)	D&B Losses (%)	Amount Billed (Rs. Cr.)	Amount Realized (Rs. Cr.)	Coll. Eff. (%)	Average Rate of billing (Rs./Kwh)	Energy Realized (MU)	AT&C Losses (%)
Badli	610.14	565.53	7.31%	487.55	490.95	100.70%	8.62	569.48	6.66%
Bawana	1177.19	995.20	15.46%	935.28	940.47	100.56%	9.40	1000.72	14.99%
Civil Lines	732.12	690.74	5.65%	577.38	569.47	98.63%	8.36	681.28	6.94%
Keshav Puram	699.94	663.32	5.23%	581.53	585.23	100.64%	8.77	667.54	4.63%
Mangolpuri	721.47	644.60	10.66%	466.75	466.83	100.02%	7.24	644.71	10.64%
Model Town	500.67	468.03	6.52%	378.46	376.74	99.55%	8.09	465.91	6.94%
Moti Nagar	806.32	756.78	6.14%	672.40	674.67	100.34%	8.88	759.34	5.83%
Narela	1147.00	1004.08	12.46%	903.66	904.74	100.12%	9.00	1005.29	12.36%
Pitam Pura	639.27	602.49	5.75%	490.95	489.17	99.64%	8.15	600.31	6.09%
Rohini	835.27	795.41	4.77%	628.71	628.21	99.92%	7.90	794.78	4.85%
Shakti Nagar	347.54	320.81	7.69%	264.06	264.07	100.00%	8.23	320.81	7.69%
Shalimar Bagh	823.07	753.53	8.45%	548.91	547.40	99.72%	7.28	751.45	8.70%
TPDDL Total	9040.00	8260.52	8.62%	6935.64	6937.95	100.03%	8.40	8263.28	8.59%

Note:-

1. All the above figures have been truncated to two decimal places. Energy Realized (MU) data (at TPDDL level) has been calculated as per average billing rate(at TPPDL level).