



TATA POWER-DDL

TPDDL/REGULATORY/2025-26/03/133
July 03, 2025

Office of the Head (Regulatory)

The Secretary

Delhi Electricity Regulatory Commission
Viniyamak Bhawan, C-Block, Shivalik
Malviya Nagar, New Delhi-110017

Subject: Submission of details of electrical accidents and action taken in line with DERC (Compensation to Victims of Electrical Accidents) Regulations, 2024 for the month of June 2025.

Dear Sir,

The Hon'ble Commission had notified the DERC (Compensation to Victims of Electrical Accidents) Regulations, 2024 which was published in the official gazette on 26.07.2024. With their publication in the official gazette, these Regulations have come into force from 26.07.2024 as provided in these Regulations.

Further, these Regulations provide for submission to the Hon'ble Commission by 15th of every succeeding month, the details of electrical accidents occurring within the respective jurisdiction of the distribution licensee and action taken thereon in accordance with these Regulations. Same is reproduced below for ready reference:

"18. Information to the Commission: -

The generating company or transmission licensee or distribution licensee shall submit to the Commission by 15th of every succeeding month, the details of electrical accidents occurring within their respective jurisdiction and action taken thereon in accordance with these Regulations."

Accordingly, Tata Power-DDL is submitting the report, enclosed herewith as **Annexure-1**, for the month of June 2025 i.e. 01.06.2025 to 30.06.2025.

We hope the Hon'ble Commission would find the above in order.

Yours Sincerely,

For Tata Power Delhi Distribution Ltd.

Ritu Gupta
Head (Regulatory)

Annexure-1

S No.	Date of Incident	Zone/ District	Address/ Location	Brief Detail	TPDDL network involved?	Fatal/ non- fatal	Remarks
1	17.06.2025	Zone - 1301+1303 (D-MTN)	Advertising Board, Near Rajdhani College, Main Road (from ESI Hospital to Rajdhani College)	At 20:33 Hrs. on 17.06.25, zonal team of Z-1301+1303 received a call of current leakage in a pole near Rajdhani College. Zonal breakdown team quickly rushed to the site where PCR of Delhi Police was already present. A person of approx. 40 years age was lying in unconscious condition opposite to an Advertisement Hoarding Pole. Delhi Police staff informed that the person got electric shock. Since there was heavy water logging near the Iron Pole of Adv. Hoarding, electric supply of the same was immediately disconnected by zonal team in the presence of Delhi Police staff. On further inspection, it was found that the concerned energy meter was feeding to no. of such Adv. Hoarding poles and the outgoing wirings from one pole to other was damaged at no. of places because of which there was current leakage in the Iron Pole. Name of the deceased - Unknown	No	Fatal	The Electrical Inspector has been informed and the enquiry report is awaited.

