



TATA POWER-DDL

TPDDL/REGULATORY/2024-25/03/ 256
Oct 14, 2024

Office of the HoD (Regulatory & Legal)

The Secretary

Delhi Electricity Regulatory Commission
Viniyamak Bhawan, C-Block, Shivalik
Malviya Nagar, New Delhi-110017

Subject: Submission of details of electrical accidents and action taken in line with DERC (Compensation to Victims of Electrical Accidents) Regulations, 2024 for the month of Sep 2024.

Dear Sir,

The Hon'ble Commission had notified the DERC (Compensation to Victims of Electrical Accidents) Regulations, 2024 which was published in the official gazette on 26.07.2024. With their publication in the official gazette, these Regulations have come into force from 26.07.2024 as provided in these Regulations.

Further, these Regulations provide for submission to the Hon'ble Commission by 15th of every succeeding month, the details of electrical accidents occurring within the respective jurisdiction of the distribution licensee and action taken thereon in accordance with these Regulations. Same is reproduced below for ready reference:

"18. Information to the Commission: -

The generating company or transmission licensee or distribution licensee shall submit to the Commission by 15th of every succeeding month, the details of electrical accidents occurring within their respective jurisdiction and action taken thereon in accordance with these Regulations."

Accordingly, Tata Power-DDL is submitting the report, enclosed herewith as **Annexure-1**, for the month of Sep 2024 i.e. 01.09.2024 to 30.09.2024.

We hope the Hon'ble Commission would find the above in order.

Yours Sincerely,
For Tata Power Delhi Distribution Ltd.

for Manish Jain

Anurag Bansal
HoD (Regulatory & Legal)

Encl: As mentioned above

Page 1 of 1

TATA POWER DELHI DISTRIBUTION LIMITED

(A Tata Power and Delhi Government Joint Venture)

Corporate Office : NDPL House Hudson Lines Kingsway Camp Delhi - 110 009

Website : www.tatapower-ddl.com CIN No. : U40109DL2001PLC111526

Annexure-1

S No.	Date of Incident	Zone/ District	Address/ Location	Brief Detail	TPDDL network involved?	Fatal/ non-fatal	Remarks
1	17.09.2024	Zone-516/ D-BDL	Near Factory No-01, Phase-02, Badli Industrial Area, Delhi-110042	<p>At about 10:07 Hrs., a No Current Complaint was received informing about a person receiving electric shock. On duty ZSO immediately got the supply of the relevant HT feeder switched OFF from PSC and reached at site at 10:11 Hrs. and found that a person was lying on ground in unconscious condition. An HT conductor was also found broken at site. After 2-3 minutes only, Delhi Police staff reached at site who took the person to nearby hospital where he was declared brought dead by the doctors. On further investigation with Delhi Police staff at site, it was found that an unknown truck pulled the internet and cable TV wire mesh which got stuck on top part of truck, resulting in breakage of those cables as well as an HT conductor along with guard wires installed below the HT conductors. The deceased person got in arcing zone of HT conductor due to breakage of guard wires also.</p> <p>Name of the deceased – Mr. Om Prakash s/o Mr. Sabhajeet Yadav Age – Approx. 50 years Address – A-35/2, Gali No.-5, Suraj Park, Badli, Delhi</p>	Yes	Fatal	The Electrical Inspector has been informed and the enquiry report is awaited.

