



TATA POWER-DDL

TPDDL/REGULATORY/2025-26/03/ 275
Oct 08, 2025

Office of the Head (Regulatory, RM, Corp.
Finance & Treasury)

The Secretary

Delhi Electricity Regulatory Commission
Viniyamak Bhawan, C-Block, Shivalik
Malviya Nagar, New Delhi-110017

Subject: Submission of details of electrical accidents and action taken in line with DERC (Compensation to Victims of Electrical Accidents) Regulations, 2024 for the month of Sep 2025.

Dear Sir,

The Hon'ble Commission had notified the DERC (Compensation to Victims of Electrical Accidents) Regulations, 2024 which was published in the official gazette on 26.07.2024. With their publication in the official gazette, these Regulations have come into force from 26.07.2024 as provided in these Regulations.

Further, these Regulations provide for submission to the Hon'ble Commission by 15th of every succeeding month, the details of electrical accidents occurring within the respective jurisdiction of the distribution licensee and action taken thereon in accordance with these Regulations. Same is reproduced below for ready reference:

"18. Information to the Commission: -

The generating company or transmission licensee or distribution licensee shall submit to the Commission by 15th of every succeeding month, the details of electrical accidents occurring within their respective jurisdiction and action taken thereon in accordance with these Regulations."

Accordingly, Tata Power-DDL is submitting the report, enclosed herewith as **Annexure-1**, for the month of Sep 2025 i.e. 01.09.2025 to 30.09.2025.

We hope the Hon'ble Commission would find the above in order.

Yours Sincerely,

For **Tata Power Delhi Distribution Ltd.**

Ritu Gupta

Head (Regulatory, RM, Corp. Finance & Treasury)

Annexure-1

S No.	Date of Incident	Zone/ District	Address/ Location	Brief Detail	TPDDL network involved?	Fatal/ non-fatal	Remarks
1	09.09.2025	Zone - 519 (D-MGP)	H. No.72, Pocket - 1, Sector - 21 Rohini	On 09-09-2025, at approximately 01:30 PM a complain (Complain NO. 2042355723) was received at the TPDDL call centre regarding current leakage at House No. 72, Pocket 1 sector - 21 Rohini. The Telephone Operator (TO) immediately inform to the breakdown team, Zonal Shift officer (ZSO) on duty on the No current complain (NCC) Team. On duty ZSO Promptly switched off power supply remotely via the Power System Control (PSC) & immediately proceeded to the complainant location. Upon reaching the site, the Zonal officer found one person (Male) unconscious in the lift Pit of the building. The police team was already present at the location. As per the information gathered from site, Mr, Vicky Sharma (the Supervisor) and victim Mr. Imran were working inside the pit of lift for waterproofing work. suddenly, Imran fell unconscious. He then immediately informed the residents of the building, who subsequently called the PCR (Recorded under DD No. 92) Unsafe Wiring notice served to five electrical meter holders. Disconnection of electric Supply to all five associated meters as a precautionary measure.	No	Fatal	The Electrical Inspector has been informed and the enquiry report is awaited.
2	21.09.2025	Zone - 523 (D-MGP)	House No.1, Gali No. 1, BLK - 1, Anand Vihar Gaurav Nagar Delhi 110041	On Dated 21-09-2025at around 13.10 PM, a complain received regarding tripping of panel No. 3 of Nithari Booster Pump substation of Nithari booster Pump. The Telephone Operator (TO) of Zone 523 immediately inform to the breakdown team as well as the Zonal Shift officer (ZSO) on duty. Immediately on duty ZSO reached the location of RMU at Nithari Booster Pump substation and found that	Yes, But not related to work (Network touched by lifting of hoarding)	Fatal -(1) Non Fatal- (1)	The Electrical Inspector has been informed and the enquiry report is awaited.



S No.	Date of Incident	Zone/ District	Address/ Location	Brief Detail	TPDDL network involved?	Fatal/ non-fatal	Remarks
				panel No. 3 of RMU was tripped after as per standard operating procedure. ZSO Started patrolling of Feeder to identify the cause of tripping. While patrolling ZSO observed that one big hoarding board hanging on 11KV line Infront of Prince Dhaba at House No.1, Gali No. 1, BLK – 1, Anand Vihar Gaurav Nagar Delhi 110041. At That time, ZSO was informed by local public that 2 persons got electrocuted while lifting the hoarding board from ground floor to the First floor of the building. Necessary site photographs were taken by ZSO and supply was restored after removing the hoarding board with the help of operating Rod against PSC reference No. TRBL659175 -L. Moreover, this is to bring to your kind notice that consumer did not inform TPDDL regarding any lifting work to be carried out in the vicinity of 11KV feeder nor he sought any permission before carrying out the activity of placing the hoardings as well as this incident.			

