



TATA POWER-DDL

TPDDL/REGULATORY/2024-25/03/ 344
Jan 02, 2025

Office of the Head (Regulatory)

The Secretary
Delhi Electricity Regulatory Commission
Viniyamak Bhawan, C-Block, Shivalik
Malviya Nagar, New Delhi-110017

Subject: Submission of details of electrical accidents and action taken in line with DERC (Compensation to Victims of Electrical Accidents) Regulations, 2024 for the month of Dec 2024.

Dear Sir,

The Hon'ble Commission had notified the DERC (Compensation to Victims of Electrical Accidents) Regulations, 2024 which was published in the official gazette on 26.07.2024. With their publication in the official gazette, these Regulations have come into force from 26.07.2024 as provided in these Regulations.

Further, these Regulations provide for submission to the Hon'ble Commission by 15th of every succeeding month, the details of electrical accidents occurring within the respective jurisdiction of the distribution licensee and action taken thereon in accordance with these Regulations. Same is reproduced below for ready reference:

"18. Information to the Commission: -

The generating company or transmission licensee or distribution licensee shall submit to the Commission by 15th of every succeeding month, the details of electrical accidents occurring within their respective jurisdiction and action taken thereon in accordance with these Regulations."

Accordingly, Tata Power-DDL is submitting the report, enclosed herewith as **Annexure-1**, for the month of Dec 2024 i.e. 01.12.2024 to 31.12.2024.

We hope the Hon'ble Commission would find the above in order.

Yours Sincerely,
For Tata Power Delhi Distribution Ltd:

Ritu Gupta
Head (Regulatory)

Encl: As mentioned above

Annexure-1

S No.	Date of Incident	Zone/ District	Address/ Location	Brief Detail	TPDDL network involved?	Fatal/ non-fatal	Remarks
1	18.12.2024	STS North-2	H. No. RZ B-1/2, Raghu Nagar, Delhi- 110045	<p>At about 00.42 hrs. on 18.12.2024, tripping was experienced on 220kV Pappankalan to Rewari Line. During patrolling of the circuit, nothing could be identified during night hours. Next day, again patrolling was done, and some crowd was found gathered around a dead body between Tower No.-3 and 4. Delhi Police staff was also present at site. As per primary information the person was a thief and was trying to steal (and escape) some aluminium profile channels from a locked building which was illegally built under the 66kV line. During this, the channels came in the arcing zone of the live line and the person got electrocuted. This circuit is owned by BRPL but maintained by Tata Power-DDL. Unauthorized Construction Notice vide No.-802320 dated 29.05.2024 was found already issued at the said premises.</p> <p>Name of the Deceased - Unknown</p>	Yes	Fatal	The Electrical Inspector has been informed and the enquiry report is awaited.

