



**TATA POWER-DDL**

TPDDL/REGULATORY/2024-25/03/ 322  
Dec 11, 2024

Office of the Head (Regulatory)

**The Secretary**

Delhi Electricity Regulatory Commission  
Viniyamak Bhawan, C-Block, Shivalik  
Malviya Nagar, New Delhi-110017

**Subject: Submission of details of electrical accidents and action taken in line with DERC (Compensation to Victims of Electrical Accidents) Regulations, 2024 for the month of Nov 2024.**

Dear Sir,

The Hon'ble Commission had notified the DERC (Compensation to Victims of Electrical Accidents) Regulations, 2024 which was published in the official gazette on 26.07.2024. With their publication in the official gazette, these Regulations have come into force from 26.07.2024 as provided in these Regulations.

Further, these Regulations provide for submission to the Hon'ble Commission by 15<sup>th</sup> of every succeeding month, the details of electrical accidents occurring within the respective jurisdiction of the distribution licensee and action taken thereon in accordance with these Regulations. Same is reproduced below for ready reference:

**"18. Information to the Commission: -**

*The generating company or transmission licensee or distribution licensee shall submit to the Commission by 15th of every succeeding month, the details of electrical accidents occurring within their respective jurisdiction and action taken thereon in accordance with these Regulations."*

Accordingly, Tata Power-DDL is submitting the report, enclosed herewith as **Annexure-1**, for the month of Nov 2024 i.e. 01.11.2024 to 30.11.2024.

We hope the Hon'ble Commission would find the above in order.

Yours Sincerely,  
For **Tata Power Delhi Distribution Ltd.**

**Ritu Gupta**  
Head (Regulatory)

**Encl:** As mentioned above

# Annexure-1

S No.	Date of Incident	Zone/ District	Address/ Location	Brief Detail	TPDDL network involved?	Fatal/ non-fatal	Remarks
1	06.11.2024	Zone-516/ D-Badli	Plot No.- E-9/46, 1 <sup>st</sup> Floor, Shahbad Dairy, Delhi (CA No.- 60019999105 as per TPDDL records)	<p>On 08.11.2024, the zonal team came to know of an unfortunate incident of Electrocution of a person in Shahbad Dairy area through Newspaper. On further investigation by the zonal manager, it was found that the said accident took place on 06.11.2024 at about 17:30 hrs. wherein a person was transporting a 20 feet iron rod from the 1<sup>st</sup> floor of an under-construction building. During this, he could maintain his balance and came in the arcing zone of nearby 11 kV line and got electric shock. He was immediately taken to the nearby hospital where doctors declared him brought dead.</p> <p><b>Name of the deceased – Sh. Chander Shekhar</b> <b>Age – Approx. 50 years.</b></p>	Yes	Fatal	The Electrical Inspector has been informed and the enquiry report is awaited.
2	06.11.2024	Zone-517/ D-NRL	H. No.- 25, Village- Jhangolla, Delhi	<p>In the evening hours of 06.11.2024, a call was received from local public regarding electric shock to a child in Village- Jhangolla. On duty ZSO of Z-517 (Bhaktawarpur) immediately rushed to the site. Local public informed him that the said child was playing on the roof of his house when he came in the arcing zone of 11 kV line. He was taken to hospital by his family members. It was visible at site that the subject premises was illegally constructed below the 11 kV circuit of TPDDL.</p> <p><b>Name of the deceased – Sh. Vanshdeep</b> <b>Age – Approx. 03 years.</b></p>	Yes	Fatal	The Electrical Inspector has been informed and the enquiry report is awaited.

