



TATAPOWER-DDL

TPDDL/REGULATORY/2024-25/03/ 230
Sep 27, 2024

Office of the HoD (Regulatory & Legal)

The Secretary

Delhi Electricity Regulatory Commission
Viniyamak Bhawan, C-Block, Shivalik
Malviya Nagar, New Delhi-110017

Subject: Submission of details of electrical accidents and action taken in line with DERC (Compensation to Victims of Electrical Accidents) Regulations, 2024 for the month of Aug 2024.

Dear Sir,

The Hon'ble Commission had notified the DERC (Compensation to Victims of Electrical Accidents) Regulations, 2024 which was published in the official gazette on 26.07.2024. With their publication in the official gazette, these Regulations have come into force from 26.07.2024 as provided in these Regulations.

Further, these Regulations provide for submission to the Hon'ble Commission by 15th of every succeeding month, the details of electrical accidents occurring within the respective jurisdiction of the distribution licensee and action taken thereon in accordance with these Regulations. Same is reproduced below for ready reference:

"18. Information to the Commission: -

The generating company or transmission licensee or distribution licensee shall submit to the Commission by 15th of every succeeding month, the details of electrical accidents occurring within their respective jurisdiction and action taken thereon in accordance with these Regulations."

Accordingly, Tata Power-DDL is submitting the report, enclosed herewith as **Annexure-1**, for the month of Aug 2024 i.e. 01.08.2024 to 31.08.2024.

We hope the Hon'ble Commission would find the above in order.

Yours Sincerely,

For Tata Power Delhi Distribution Ltd.

for Manish Jain

Anurag Bansal

HoD (Regulatory & Legal)

Encl: As mentioned above

Annexure-1

S No.	Date of Incident	Zone/ District	Address/ Location	Brief Detail	TPDDL network involved?	Fatal/ non-fatal	Remarks
1	01.08.2024	Z-507/ D-BDL	Plot No. 56, Khasra No. 24/7,66 Futa Road, Block-A, Ambey Garden, Libaspur, Delhi - 110042, (As per TPDDL Record CA NO. 60011255043)	At about 19:20 Hrs., a person got electric shock while he was shifting a long iron rod from 1 st floor in a factory. The rod came in the arcing zone of 11 kV network via balcony of the house. He was taken to nearby hospital by factory owner where he was declared brought dead by the doctors.	Yes	Fatal	The enquiry report from the Electrical Inspector dated 04.09.24 has been received and the concerned authority shall pass appropriate orders within 30 days in line with DERC (Compensation to Victims of Electrical Accidents) Regulations, 2024.

