

## Summary of Overall Standards of Performance

Name of Company TATA Power-DDL  
 Period of Report Q1  
 Year 2019-20

Sl.No.	Service Area	Overall Standards of Performance	Total Cases Received/ Reported (A)	Complaints Attended (B)		Standard of Performance achieved (%) (C)
				Within Specified Time	Beyond specified time	
1	Power Supply Failure					
(i)	Continuous power failure affecting individual consumer and group of consumer upto 100 connected at Low voltage supply, excluding the failure where distribution transformer requires replacement.	At least 95% calls received should be rectified within prescribed time limits under Schedule-1	113067	113037	30	99.97
(ii)	Continuous power failure affecting more than 100 consumers connected at Low voltage supply excluding the failure where distribution transformer requires replacement.		52926	52809	117	99.78
(iii)	Continuous power supply failure requiring replacement of distribution transformer.		533	527	6	98.87
(iv)	Continuous power failure affecting consumers connected through High Voltage Distribution System (HVDS) and not covered under (i) & (ii) above		25337	25311	26	99.90
(v)	Continuous scheduled power outages		3638	3635	3	99.92
(vi)	Replacement of burnt meter or stolen meter		1828	1828	0	100.00

Sl.No.	Service Area	Overall Standards of Performance	Total Cases Received/ Reported (A)	Complaints Attended (B)		Standard of Performance achieved (%) (C)
				Within Specified Time	Beyond specified time	
<b>Period of scheduled outage</b>						
2	Maximum duration in a single stretch	At least 95% of cases resolved within time limit	1832	1832	0	100
	Restoration of supply by 6:00 PM		1832	1815	17	99.07
3	Faults in street light maintained by the Licensee	At least 90% cases should be complied within prescribed time limits	40876	40854	22	99.95
<b>Reliability Indices</b>						
4	SAIFI	To be laid down by the Commission based on the targets proposed by the Licensees	0.815			
	SAIDI		0.612			
	CAIDI		1			
5	Frequency variation	To maintain supply frequency within range as per IEGC	0	0	0	-
6	Voltage imbalance	Maximum of 3% at point of commencement of supply	0	0	0	-
7	Percentage billing mistakes	Shall not exceeding 0.2%	1967	1742	2	0.03