

Summary of Overall Standards of Performance

Name of Company TATA Power-DDL
 Period of Report Q3
 Year FY 20-21

Sl.No.	Service Area	Overall Standards of Performance	Total Cases Received/ Reported (A)	Complaints Attended (B)		Standard of Performance achieved (%) (C)
				Within Specified Time	Beyond specified time	
1	Power Supply Failure					
(i)	Continuous power failure affecting individual consumer and group of consumer upto 100 connected at Low voltage supply, excluding the failure where distribution transformer requires replacement.	At least 95% calls received should be rectified within prescribed time limits under Schedule-1	39527	39508	19	99.95
(ii)	Continuous power failure affecting more than 100 consumers connected at Low voltage supply excluding the failure where distribution transformer requires replacement.		12049	11994	54	99.54
(iii)	Continuous power supply failure requiring replacement of distribution transformer.		34	34	0	100.00
(iv)	Continuous power failure affecting consumers connected through High Voltage Distribution System (HVDS) and not covered under (i) & (ii) above		15883	15868	15	99.91
(v)	Continuous scheduled power outages		1881	1867	14	99.26
(vi)	Replacement of burnt meter or stolen meter		2162	2162	0	100.00

Sl.No.	Service Area	Overall Standards of Performance	Total Cases Received/ Reported (A)	Complaints Attended (B)		Standard of Performance achieved (%) (C)
				Within Specified Time	Beyond specified time	
Period of scheduled outage						
2	Maximum duration in a single stretch	At least 95% of cases resolved within time limit	2490	2487	3	99.88
	Restoration of supply by 6:00 PM		2490	2478	12	99.52
3	Faults in street light maintained by the Licensee	At least 90% cases should be complied within prescribed time limits	34446	34397	49	99.86
Reliability Indices						
4	SAIFI	To be laid down by the Commission based on the targets proposed by the Licensees	0.354			
	SAIDI		0.212			
	CAIDI		0.60			
5	Frequency variation	To maintain supply frequency within range as per IEGC	0	0	0	–
6	Voltage imbalance	Maximum of 3% at point of commencement of supply	0	0	0	–
7	Percentage billing mistakes	Shall not exceeding 0.2%	1409	1313	0	0.03