Summary of Overall Standards of Performance

Name of Company	TATA Power-DDL
Period of Report	FY
FY	2024-25

			Total Cases Complaints		Attended	Standard of		
SI.No.	Service Area	Overall Standards of Performance	Received/ Reported (A)	Within Specified Time	Beyond specified time	Performance achieved (%) (C)		
1	1 Power Supply Failure Continuous power failure							
(i)	affecting individual consumer and group of consumer upto 100 connected at Low voltage supply, excluding the failure where distribution transformer requires replacement.		213969	213902	67	99.97		
(ii)	Continuous power failure affecting more than 100 consumers connected at Low voltage supply excluding the failure where distribution transformer requires replacement.	At least 95% calls received should be rectified within prescribed time limits	75975	75678	297	99.61		
(iii)	Continuous power supply failure requiring replacement of distribution transformer.		547	533	14	97.44		
(iv)	Continuous power failure affecting consumers connected through High Voltage Distribution System (HVDS) and not covered under (i) & (ii) above		93145	93072	73	99.92		
(v)	Continuous scheduled power outages		4173	4162	11	99.74		
(vi)	Replacement of burnt meter or stolen meter		3385	3385	0	100.00		
		Period of sch	eduled outage					
2	Maximum duration in a single stretch	At least 95% of cases resolved within	7881	7880	1	99.99		
2	Restoration of supply by 6:00 PM		7881	7816	65	99.18		
3	Faults in street light maintained by the Licensee	At least 90% cases should be complied within prescribed time limits	158364	158273	91	99.94		
	Γ	,	Indices					
	SAIFI	To be laid down by the Commission	1.110					
4	SAIDI	based on the targets proposed by the	0.829					
CAIDI				0.747				
5	Frequency variation	To maintain supply frequency within range as per IEGC	0	0	0	_		
6	Voltage imbalance	Maximum of 3% at point of commencement of supply	0	0	0	_		
7	Percentage billing mistakes	Shall not exceeding 0.2%	6198	5745	3	0.02		
Thora are	opening cases being attended during the	warm Cincilanty and a suist h	aima na aniva d'Anna	المحجب حطاف سمائس باحام مغس				

There are opening cases being attended during the year. Similarly cases exist being received /reported during the year but carried forward to next year.